

Optimal control of a solar-driven humidification-dehumidification desalination plant

MOHAMED ABDELBAR SHAMSELDIN ALY, Bahy Gabra, Mohamed Rady & A. M. Abdel Ghany

Abstract

This article reports on mathematical modelling and control of a solar-driven humidification-dehumidification desalination plant. Mathematical models for the components are constructed using CARNOT toolbox in MATLAB environment. Model validation has been shown by comparison with published experimental data. Solar collector outlet temperature control is a key parameter to optimize plant performance. In this study, solar field pump flow rate is controlled to maintain the collector outlet temperature at a predetermined set value. Three types of PID controllers are tested. These include PID, nonlinear PID and fractional-order PID. Controllers' gains are optimized using genetic algorithm technique. The results show that FOPID controller offers a superior dynamic and static performance and can be automatically adjusted to compensate for weather changes.

Journal of Electrical Systems and Information Technology 2019, December